

FONCTION APPROCHE CAT I 720m								
N° DE FEU	Type de feu	PUISSANCE TOTALE FEU + CABLE SEC	T.I.	RENDEMENT	BOUCLE	PUISSANCE BOUCLE 1	PUISSANCE BOUCLE 2	
1	ELEVE	45.78	45	0.865	1	54.00	0.00	
2	ELEVE	46.01	45	0.865	2	0.00	54.28	
3	ELEVE	46.23	45	0.865	1	54.54	0.00	
4	ELEVE	46.35	45	0.865	2	0.00	54.68	
5	ELEVE	47.12	45	0.865	1	55.59	0.00	
6	ELEVE	47.12	45	0.865	1	55.59	0.00	
7	ELEVE	47.12	45	0.865	2	0.00	55.59	
8	ELEVE	47.12	45	0.865	1	55.59	0.00	
9	ELEVE	47.12	45	0.865	2	0.00	55.59	
10	ELEVE	47.12	45	0.865	2	0.00	55.59	
11	ELEVE	47.12	45	0.865	1	55.59	0.00	
12	ELEVE	47.12	45	0.865	2	0.00	55.59	
13	ELEVE	47.12	45	0.865	1	55.59	0.00	
14	ELEVE	47.09	45	0.865	2	0.00	55.55	
15	ELEVE	47.11	45	0.865	1	55.57	0.00	
16	ELEVE	47.16	45	0.865	2	0.00	55.63	
17	ELEVE	46.28	45	0.865	1	54.59	0.00	
18	ELEVE	47.34	45	0.865	2	0.00	55.85	
19	ELEVE	47.34	45	0.865	1	55.85	0.00	
20	ELEVE	47.34	45	0.865	2	0.00	55.85	
21	ELEVE	47.34	45	0.865	1	55.85	0.00	
22	ELEVE	47.34	45	0.865	2	0.00	55.85	
23	ELEVE	47.34	45	0.865	1	55.85	0.00	
24	ELEVE	47.34	45	0.865	1	55.85	0.00	
25	ELEVE	47.34	45	0.865	2	0.00	55.85	
26	ELEVE	47.34	45	0.865	1	55.85	0.00	
27	ELEVE	47.34	45	0.865	2	0.00	55.85	
28	ELEVE	47.34	45	0.865	1	55.85	0.00	
29	ELEVE	46.95	45	0.865	1	55.38	0.00	
30	ELEVE	46.95	45	0.865	1	55.38	0.00	
31	ELEVE	47.21	45	0.865	2	0.00	55.69	
32	ELEVE	47.21	45	0.865	2	0.00	55.69	
33	ELEVE	47.40	45	0.865	1	55.92	0.00	
34	ELEVE	47.99	45	0.865	1	56.61	0.00	
35	ELEVE	48.27	45	0.865	2	0.00	56.94	
36	ELEVE	48.27	45	0.865	2	0.00	56.94	
37	ELEVE	48.51	45	0.865	1	57.22	0.00	
38	ELEVE	48.51	45	0.865	1	57.22	0.00	
39	ELEVE	48.51	45	0.865	1	57.22	0.00	
40	ELEVE	48.51	45	0.865	2	0.00	57.22	
41	ELEVE	48.51	45	0.865	1	57.22	0.00	
42	ELEVE	48.51	45	0.865	2	0.00	57.22	
43	ELEVE	48.51	45	0.865	1	57.22	0.00	
44	ELEVE	48.51	45	0.865	2	0.00	57.22	
45	ELEVE	48.51	45	0.865	2	0.00	57.22	
46	ELEVE	48.51	45	0.865	1	57.22	0.00	
47	ELEVE	48.51	45	0.865	2	0.00	57.22	
48	ELEVE	48.51	45	0.865	1	57.22	0.00	
49	ELEVE	48.51	45	0.865	2	0.00	57.22	
50	ELEVE	48.51	45	0.865	1	57.22	0.00	
51	ELEVE	48.73	45	0.865	2	0.00	57.48	
52	ELEVE	48.73	45	0.865	2	0.00	57.48	
53	ELEVE	48.73	45	0.865	1	57.49	0.00	
54	ELEVE	48.73	45	0.865	1	57.49	0.00	
55	ELEVE	48.62	45	0.865	2	0.00	57.36	
56	ELEVE	48.62	45	0.865	2	0.00	57.36	
57	ELEVE	48.81	45	0.865	1	57.58	0.00	
58	ELEVE	48.81	45	0.865	1	57.58	0.00	
59	ELEVE	49.23	45	0.865	2	0.00	58.07	
60	ELEVE	49.23	45	0.865	2	0.00	58.07	
61	ELEVE	49.23	45	0.865	1	58.07	0.00	
62	ELEVE	49.23	45	0.865	2	0.00	58.07	
63	ELEVE	49.23	45	0.865	1	58.07	0.00	
64	ELEVE	49.23	45	0.865	2	0.00	58.07	
65	ELEVE	49.23	45	0.865	1	58.07	0.00	
66	ELEVE	49.23	45	0.865	2	0.00	58.07	
67	ELEVE	49.23	45	0.865	1	58.07	0.00	
68	ELEVE	49.23	45	0.865	1	58.07	0.00	
69	ELEVE	49.23	45	0.865	2	0.00	58.07	
70	ELEVE	49.23	45	0.865	1	58.07	0.00	
71	ELEVE	49.23	45	0.865	2	0.00	58.07	
72	ELEVE	49.23	45	0.865	1	58.07	0.00	
73	ELEVE	49.23	45	0.865	2	0.00	58.07	
74	ELEVE	49.23	45	0.865	1	58.07	0.00	
75	ELEVE	49.30	45	0.865	1	58.16	0.00	
76	ELEVE	49.30	45	0.865	1	58.16	0.00	
77	ELEVE	49.30	45	0.865	1	58.16	0.00	
78	ELEVE	49.60	45	0.865	2	0.00	58.51	
79	ELEVE	49.60	45	0.865	2	0.00	58.51	
80	ELEVE	49.60	45	0.865	2	0.00	58.51	
81	ELEVE	49.82	45	0.865	1	58.77	0.00	
82	ELEVE	49.82	45	0.865	1	58.77	0.00	
83	ELEVE	49.82	45	0.865	1	58.77	0.00	
84	ELEVE	50.03	45	0.865	2	0.00	59.02	
85	ELEVE	50.03	45	0.865	2	0.00	59.02	
86	ELEVE	50.03	45	0.865	2	0.00	59.02	
SECTION SECONDAIRE : 4						<b>TOTAL</b>	<b>2558.32</b>	<b>2337.16</b>
						<b>CABLE PRIMAIRE (m)</b>	5000	5000
						<b>PERTE</b>	653.4	653.4
						<b>PUISSANCE</b>	<b>3211.72</b>	<b>2990.56</b>
						<b>TENSION</b>	<b>487</b>	<b>453</b>